



Certificate of Compliance

Certificate: 1205719 Master Contract: 185051 (103378_0_000)

Project: 70095546 Date Issued: 2016-10-12

Issued to: SUCO Robert Scheuffele GmbH & Co. KG
Keplerstr 12 - 14
Bietigheim-Bissingen, 74321
GERMANY
Attention: Martin Selzer

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.



Issued by: Rowell Manipula
Rowell Manipula

PRODUCTS

CLASS - C323102 - SWITCHES-Automatic - Pressure Type

CLASS - C323182 - SWITCHES-Automatic - Pressure Type - Certified to US Standards

Pressure switches, DS

Type	Current	Voltage	Max. Power	Switch	NO/NC	No. operations
0110	4A Max	42Vac Max	100VA	spst	NO/NC	100.000
0111	4A Max	42Vac Max	100VA	spst	NO/NC	100.000
0112	4A Max	42Vac Max	100VA	spst	NO/NC	100.000
0113	4A Max	42Vac Max	100VA	spst	NO/NC	100.000
0114	4A Max	42Vac Max	100VA	spst	NO/NC	100.000
0115	4A Max	42Vac Max	100VA	spst	NO/NC	100.000
0116	4A Max	42Vac Max	100VA	spst	NO/NC	100.000
0117	4A Max	42Vac Max	100VA	spst	NO/NC	100.000
0118	4A Max	42Vac Max	100VA	spst	NO/NC	100.000
0119	4A Max	42Vac Max	100VA	spst	NO/NC	100.000
0120	4A Max	42Vac Max	100VA	spst	NO/NC	100.000
0121	4A Max	42Vac Max	100VA	spst	NO/NC	100.000
0122	4A Max	42Vac Max	100VA	spst	NO/NC	100.000
0123	4A Max	42Vac Max	100VA	spst	NO/NC	100.000



Certificate: 1205719
Project: 70095546

Master Contract: 185051
Date Issued: 2016-10-12

0132	4A Max	48Vac Max	100VA	spdt	NO/NC	100.000
0133	4A Max	48Vac Max	100VA	spdt	NO/NC	100.000
0134	4A Max	48Vac Max	100VA	spdt	NO/NC	100.000
0135	4A Max	48Vac Max	100VA	spdt	NO/NC	100.000
0136	4A Max	48Vac Max	100VA	spdt	NO/NC	100.000
0137	4A Max	48Vac Max	100VA	spdt	NO/NC	100.000
0151	4A Max	42Vac Max	100VA	spst	NO/NC	100.000
0163	4A Max	42Vac Max	100VA	spst	NO/NC	100.000
0164	4A Max	42Vac Max	100VA	spst	NO/NC	100.000
0166	4A Max	42Vac Max	100VA	spst	NO/NC	100.000
0167	4A Max	42Vac Max	100VA	spst	NO/NC	100.000
0168	4A Max	42Vac Max	100VA	spst	NO/NC	100.000
0169	4A Max	42Vac Max	100VA	spst	NO/NC	100.000
0170	4A Max	42Vac Max	100VA	spdt	NO/NC	100.000
0171	4A Max	42Vac Max	100VA	spdt	NO/NC	100.000
0180	4A Max	250Vac Max		spdt	NO/NC	100.000
0181	4A Max	250Vac Max		spdt	NO/NC	100.000
0184	4A Max	250Vac Max		spdt	NO/NC	100.000
0185	4A Max	250Vac Max		spdt	NO/NC	100.000
0186	4A Max	250Vac Max		spdt	NO/NC	100.000
0187	4A Max	250Vac Max		spdt	NO/NC	100.000
0190	50mA	24V Max		spdt	NO/NC	100.000
0191	50mA	24V Max		spdt	NO/NC	100.000
0194	50mA	24V Max		spdt	NO/NC	100.000
0195	50mA	24V Max		spdt	NO/NC	100.000
0196	50mA	24V Max		spdt	NO/NC	100.000
0197	50mA	24V Max		spdt	NO/NC	100.000

May be provided with optional CSA certified or UL listed plug-in connector type 1-1-80-652-002, rated 250Vac, 4A, for pressure switches series DS 0170, 0171, 0180, 0181, 0186, 0187, 0190, 0191, 0196, 0197.

Notes:

1. Open type devices are certified as components, for use only in other certified equipment where the suitability of the combination is determined by CSA Group or another NRTL.

APPLICABLE REQUIREMENTS

CSA Standard C22.2 No. 14 - Industrial Control Equipment
 UL 508 - Industrial Control Equipment



Supplement to Certificate of Compliance

Certificate: 1205719

Master Contract: 185051 (103378_0_000)

*The products listed, including the latest revision described below,
are eligible to be marked in accordance with the referenced Certificate.*

Product Certification History

Project	Date	Description
70095546	2016-10-12	Update to the report to add alternate part numbers of Gasket.
2022787	2008-04-09	Transfer of report from SUCO Inc. and update to new standard editions